



July 25, 2013

ONEIDA CONCRETE PRODUCTS, INC.
RICK JOHNSON
1539 N STEVENS ST
PO BOX 357
RHINELANDER WI 54501

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: ONEIDA CONCRETE PRODUCTS, INC.
Product Name: SEPTIC, HOLDING, GREASE INTERCEPTOR OR PUMP
Model Number(s): 2075
(47.0" L.L., 44.2 GAL/IN. 72" MAX. DEPTH OF BURY, 995 G.P.D. WHEN USED AS A
SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR RESIDENTIAL
WASTEWATER)
Product File No: 20130161

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of July 2018.**

This approval supersedes the approval issued on 06/02/2008 under product file number 20080255.
This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20080255.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 greater than 30 mg/L but less than or equal to 220 mg/L, TSS greater than 30 mg/L but less than or equal to 150 mg/L and F.O.G. less than or equal to 30 mg/L.
- This product is approved to use the following:
 - Press Seal "Cast-A-Seal" gaskets
 - Dual or triple inlets at end of tank with one access or multiple openings above each inlet.
 - Dual or triple outlets end of tank with one access or multiple openings above each outlet.
 - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
 - Tuf-Tite manhole risers and covers.
 - Bottom and side pipe openings for siphon, pump and holding tanks.
 - Six inch inlet and outlet openings.
 - E-Z Set Risers models 2406, 2412 and 3012 cast in concrete tank cover

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones
Public Swimming Pool Plan / Plumbing Product Reviewer
phone: (608) 267-5265, fax: (608) 267-9723
email: glen.jones@wi.gov